



oneSIGHT  
SOLUTIONS

# Electronic Fan Coil Controller OSS-FCU Series

## Modbus Communication Module User Guide



OSS-FCU 10TU2 (24Vac / 2 relays)

OSS-FCU 10TU4 (24Vac / 4 relays)

OSS-FCU 11TU2 (120Vac / 2 relays)

OSS-FCU 11TU4 (120Vac / 4 relays)

OSS-FCU 12TU2 (240Vac / 2 relays)

OSS-FCU 12TU4 (240Vac / 4 relays)



## Introduction

---

The OSS-FCU Series Modbus Communication Module User Guide provides information for using Neptronic® communication feature. The controller uses Modbus communication protocol over serial line in the RTU mode and provides a Modbus network interface between client devices and Onesight Solutions OSS-FCU Series devices.

The OSS-FCU Series Modbus Guide assumes that you are familiar with Modbus terminology. The following are the requirements for Modbus:

- **Data Model.** The OSS-FCU Series Modbus server data model uses only the Holding Registers table.
- **Function Codes.** The OSS-FCU Series Modbus server supports a limited function codes subset comprising:
  - o Read Holding Registers (0x03)
  - o Write Single Register (0x06)
  - o Write Multiple Registers (0x10)
- **Exception Responses.** The OSS-FCU Series Modbus server supports the following exception codes:
  - o Illegal data address
  - o Illegal data value
  - o Slave device busy
- **Serial Line.** The OSS-FCU Series Modbus over serial line uses RTU transmission mode over a two-wire configuration RS485 (EIA/TIA-485 standard) physical layer.
  - o The physical layer can use fixed baud rate selection or automatic baud rate detection (default) as per the Modbus Auto Baud Rate device menu item or holding register index 1.
  - o The supported baud rates are 9600, 19200, 38400, and 57600.
  - o The physical layer also supports variable parity control and stop bit configuration as per the Modbus Comport Config device menu item or holding register index 2.
  - o In auto baud rate configuration, if the device detects only consecutive bad frames (2 or more) for one second with any given baud rate, it will reinitialize itself to the next baud rate.
  - o If the device does not detect any activity for one second or more, it will find a silent line to prevent a possible baud rate scan on the next frame it detects.
- **Addressing.** The OSS-FCU Series device only answers at the following address:
  - o The device's unique address (1 to 246) that can be set through the device menu or through holding register index 0.



## Holding Registers Table

### Glossary

Name	Description	Name	Description
W	Writable Register	ASCII	For registers containing ASCII (8-bit) characters
RO	Read Only Register	MSB	Most Significant Byte
Unsigned	For range of values from 0 to 65,535, unless otherwise specified	LSB	Least Significant Byte
Signed	For range of values from -32,768 to 32,767, unless otherwise specified	MSW	Most Significant Word
Bit String	For registers with multiple values using bit mask (example, flags)	LSW	Least Significant Word

### Holding Register Table

Register Index	Description	Data Type	Range	Writable
40000	Address - Onesight Solutions ID and Modbus address of current device.	Unsigned	MB = Modbus Address (e.g. 110), LB = 1-247	W

40001	MSTP Baud Rate - BaudRate of device/100.	Unsigned Scale 100	0, 9600, 19200, 38400, or 57600, 0 = Auto Baud Rate Detection Value/100 (e.g. 38400 baud = 384)	W
40002	Communication port configuration.	Unsigned	1= No parity, 2 Stop bits 2= Even parity, 1 stop bit 3= Odd parity, 1 Stop bit	W
40003	ProdName_87, characters 8-7 of 8 name characters.	ASCII	1 to 65,535 char 8: 0x0045 = E char 7: 0x0046 = F	W
40004	ProdName_65, characters 6-5 of 8 name characters.	ASCII	1 to 65,535 char 6: 0x0043 = C char 5: 0x0042 = B	W
40005	ProdName_43, characters 4-3 of 8 name characters.	ASCII	1 to 65,535 char 4: 0x0054 = T char 3: 0x0055 = U	W
40006	ProdName_21, characters 2-1 of 8 name characters.	ASCII	1 to 65,535 char 2: 0x0034 = 4 char 1: 0x0000 =	W

Register Index	Description	Data Type	Range	Writable
40007	Thermostat Product_Version, actual firmware version.	Unsigned	1 to 65,535 (e.g. 210)	RO
40008	Thermostat parameters version.	Unsigned	1 to 65,535 (e.g. 207)	RO

40009	System Status 1.	Bit String	<p>[B1, B5, B7-B11]: Reserved</p> <p>B0: System operation 0 = Normal, 1 = Fault</p> <p>B2: System override by NSB 0 = Normal, 1 = OFF</p> <p>B3: Change Over Mode 0 = Cooling, 1 = Heating</p> <p>B4: Flow Switch Alarm 0 = No alarm, 1 = Alarm activated</p>	<p>B6: Dirty Filter Alarm 0 = No alarm, 1 = Alarm activated</p> <p>B12: Analog Input 3 Mode 0 = Temp 10kΩ, 1 = 0-10Vdc</p> <p>B13: Analog Input 4 Mode 0 = Temp 10kΩ, 1 = 0-10Vdc</p> <p>B14: Analog Input 5 mode 0 = Temp 10kΩ, 1 = 0-10Vdc</p> <p>B15: Analog Input 6 Mode 0 = Temp 10kΩ, 1 = 0-10Vdc</p>	RO
40010	System Status 2.	Bit String	<p>[B0-B6, B12-B14]: Reserved</p> <p>B7: Override Alarm 0 = Off, 1 = On</p> <p>B8: Window Opened Alarm 0 = Off, 1 = On</p> <p>B9: Door Opened Alarm 0 = Off, 1 = On</p>	<p>B10: DI1 Alarm 0 = Off, 1 = On</p> <p>B11: DI2 Alarm 0 = Off, 1 = On</p> <p>B13: DI4 Alarm 0 = Off, 1 = On</p> <p>B15: Overheat Alarm 0 = Off, 1 = On</p>	RO
40011	Internal temperature sensor reading.	Unsigned Scale 100	Range: 0°C to 50°C or 32°F to 122°F Value x 100 (e.g. 23°C = 2300 or 33°F = 3300)		RO

40012	External temperature sensor reading.	Unsigned Scale 100	Range: 0°C to 50°C or 32°F to 122°F Value x 100 (e.g. 23°C = 2300 or 33°F = 3300)	RO
40013	Changeover temperature sensor reading.	Unsigned Scale 100	Range: 0°C to 50°C or 32°F to 122°F Value x 100 (e.g. 23°C = 2300 or 33°F = 3300)	RO
40014	Control temperature reading.	Unsigned Scale 100	Range: 0°C to 50°C or 32°F to 122°F Value x 100 (e.g. 23°C = 2300 or 33°F = 3300)	W
40015	Internal humidity sensor reading. Select models only.	Unsigned Scale 10	Unit: % RH, Range: 5%RH to 100%RH Value x 10 (e.g. 30%RH = 300)	RO
Register Index	Description	Data Type	Range	Writable
40016	External Humidity sensor reading. Select models only.	Unsigned Scale 10	Unit: % RH, Range: 5%RH to 100%RH Value x 10 (e.g. 30%RH = 300)	RO
40017	Analog input 3 reading.	Signed Scale 100	Unit: Volts or °C/°F, Range: 0V to 10V, -40°C to 100°C or -40°F to 212°F Value x 100 (e.g. 3 V = 300/18°C = 1800 or 33°F = 3300)	RO
40018	Analog input 4 reading.	Signed Scale 100	Unit: Volts or °C/°F, Range: 0V to 10V, -40°C to 100°C or -40°F to 212°F Value x 100 (e.g. 3 V = 300/18°C = 1800 or 33°F = 3300)	RO
40019	Analog input 5 reading.	Signed Scale 100	Unit: Volts or °C/°F, Range: 0V to 10V, -40°C to 100°C or -40°F to 212°F Value x 100 (e.g. 3 V = 300/18°C = 1800 or 33°F = 3300)	RO
40020	Analog input 6 reading.	Signed Scale 100	Unit: Volts or °C/°F, Range: 0V to 10V, -40°C to 100°C or -40°F to 212°F Value x 100 (e.g. 3 V = 300/18°C = 1800 or 33°F = 3300)	RO

40021	Digital input status of 4 digital inputs.	Bit String	<p>[B8-B15]: Reserved</p> <p>B0: Digital input 1 0 = Open, 1 = Close</p> <p>B1: Digital input 2 0 = Open, 1 = Close</p> <p>B2: Digital input 3 0 = Open, 1 = Close</p> <p>B3: Digital input 4 0 = Open, 1 = Close</p> <p>B4: AI3 Digital input 0 = Open, 1 = Close</p> <p>B5: AI4 Digital input 0 = Open, 1 = Close</p> <p>B6: AI5 Digital input 0 = Open, 1 = Close</p> <p>B7: AI6 Digital input 0 = Open, 1 = Close</p>	RO
40022	Actual system occupancy state.	Unsigned	1 = NoOccupancy   2 = Occupancy   3 = Override	RO
40023	Actual night setback state of the system. Not available on all models.	Unsigned	1 = Day   2 = Night   3 = Override	RO
40024	Actual heating demand.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40025	Actual local reheat demand.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40026	Actual cooling demand.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40027	Actual changeover demand.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40028	Actual fan demand.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO



Register Index	Description	Data Type	Range	Writable
40029	Actual dehumidification demand. Select models only.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40030	Actual humidification demand. Select models only.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40031	CL_HT_SwitchTimerCount - countdown until system is able to swap the demand.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 120 minutes, Value/1 (e.g. 5 mins =5)	RO
40032	Analog output 1 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	W
40033	Analog output 2 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	W
40034	Analog output 3 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	W
40035	Analog output 4 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	W
40036	Floating output 1 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40037	Floating output 2 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40038	Pulsing output 1 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40039	Pulsing output 2 value.	Unsigned Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO

40040	Pulsing output 3 value.	Signed Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40041	Pulsing output 4 value.	Signed Scale 10	Unit: %, Range: 0% to 100%, Value x 10 (e.g. 100% = 1000)	RO
40042	TRIAC output on-off mode status.	Bit String	<p>[B4-B15]: Reserved</p> <p>B0: On Off output 1 0 = Off, 1 = On</p> <p>B1: On Off output 2 0 = Off, 1 = On</p> <p>B2: On Off output 3 0 = Off, 1 = On</p> <p>B3: On Off output 4 0 = Off, 1 = On</p>	W

Register Index	Description	Data Type	Range	Writable
40043	Digital output - 7 relays output status.	Bit String	<p>[B7-B15]: Reserved</p> <p>B0: Digital output 1 0 = Open, 1 = Close</p> <p>B1: Digital output 2 0 = Open, 1 = Close</p> <p>B2: Digital output 3 0 = Open, 1 = Close</p> <p>B3: Digital output 4 0 = Open, 1 = Close</p> <p>B4: FAN Output High 0 = Open, 1 = Close</p> <p>B5: FAN Output Med 0 = Open, 1 = Close</p> <p>B6: FAN Output Low 0 = Open, 1 = Close</p>	W

40044	System command.	Bit String	<p>[B6, B9-B15]: Reset Address</p> <p>B0: Service Display Address on LCD 0 = Off; 1 = Display</p> <p>B1: Cooling Ramp Lock 0 = Off; 1 = On</p> <p>B2: Condensation Alarm 0 = Off; 1 = On</p> <p>B3: Heating Ramp Lock 0 = Off; 1 = On</p> <p>B4: Reheat Ramp Lock 0 = Off; 1 = On</p> <p>B5: Changeover Ramp Lock 0 = Off; 1 = On</p> <p>B7: Humidify Ramp Lock 0 = Off; 1 = On</p> <p>B8: Dehumidify Ramp Lock 0 = Off; 1 = On</p>	W
			<p>B3: Heating Ramp Lock 0 = Off; 1 = On</p>	
40045	System mode status.	Unsigned	1 = Auto   2 = Heat   3 = Cool   4 = Off	W
40046	Fan speed selection by user.	Unsigned	1 = Auto   2 = Low   3 = Med   4 = High	W
40047	Temperature setpoint in occupancy or day mode.	Signed Scale 10	Unit: Volts or °C/°F, Range: min to max setpoint Value x 10 (e.g. 3 V = 300/18°C = 180 or 60°F = 600)	W

40048	System options1.	Bit String	<p>B0: Temp unit displayed on thermostat 0 = °C, 1 = °F</p> <p>B1: Temp unit displayed in Modbus 0 = °C, 1 = °F</p> <p>B2: Temp SetPoint Lock = Off, 1 = On</p> <p>B3: Humidity SetPoint Lock 0 = Off, 1 = On</p> <p>B8: User System Off Modes 0 = Enable, 1 = Disable</p> <p>B9: Keypad Bottom Left Lock 0 = Off, 1 = On</p> <p>Keypad Upper Left Lock 0 = Off, 1 = On</p> <p>Keypad Arrows Lock 0 = Off, 1 = On</p> <p>B10: Key On = Off, 1 = On</p> <p>B11: On</p>	W
-------	------------------	------------	---	---

Register Index	Description	Data Type	Range	Writable
----------------	-------------	-----------	-------	----------

			<p>B4: Program Mode Lock 0 = Off, 1 = On</p> <p>B5: Floating TO1/TO2 Direction 0 = Direct, 1 = Reverse</p> <p>B6: Floating TO3/TO4 Direction 0 = Direct, 1 = Reverse</p> <p>B7: Freeze Protection Alarm 0 = Off, 1 = On</p> <p>B12: User Fan Auto Mode 0 = Enable, 1 = Disable</p> <p>B13: Night SetBack Mode 0 = Setpoint, 1 = OFF</p> <p>B14: Humidity Control Source 0 = Intern Sensor, 1 = Extern Sensor</p> <p>B15: Time Mode 0 = 24h, 1 = 12h</p>	
--	--	--	---	--

40049	System options 2.	Bit String	<p>[B0-B1]: Reserved</p> <p>B2: Baud Rate 0 = Auto, 1 = Manual</p> <p>B3: Schedule On or Off 0 = Off, 1 = On</p> <p>B4: Analog Output 1 Direction 0 = Direct, 1 = Reverse</p> <p>B5: Analog Output 2 Direction 0 = Direct, 1 = Reverse</p> <p>B6: Analog Output 3 Direction 0 = Direct, 1 = Reverse</p> <p>B7: Analog Output 4 Direction 0 = Direct, 1 = Reverse</p>	<p>B9: TO2 Direction 0 = Direct, 1 = Reverse</p> <p>B10: TO3 Direction 0 = Direct, 1 = Reverse</p> <p>B11: TO4 Direction 0 = Direct, 1 = Reverse</p> <p>B12: Digital Output 1 Direction 0 = Direct, 1 = Reverse</p> <p>B13: Digital Output 2 Direction 0 = Direct, 1 = Reverse</p> <p>B14: Digital Output 3 Direction 0 = Direct, 1 = Reverse</p> <p>B15: Digital Output 4 Direction 0 = Direct, 1 = Reverse</p>	W
-------	-------------------	------------	--	--	---

			B8: TO1 Direction 0 = Direct, 1 = Reverse	
40050	System option3.	Bit String	[B0, B1, B3-B15]: Reserved B2: Cfg_DisplayCO2 0 = Off, 1 = On	W
40051	System option4.		[B0-B15]: Reserved	W
40052	TFL/TDU display information.	Unsigned	1= Temperature and Demand   2= Setpoint and Demand   3= Temperature Only 4= Setpoint Only   5= Off	W

Register Index	Description	Data Type	Range	Writable
40053	Temperature control source.	Unsigned	1= Network Temp   2= Intern Temp   3= Extern Temp	W

40054	Network fallback timeout Present Value.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 60 minutes, Value/1 (e.g. 30 mins = 30)	W
40055	Minimum occupancy/day setpoint.	Signed Scale 10	Unit: Volts or °C/°F, Range: 10°C to max or 50°F to max Value x 10 (e.g. 3 V = 30/18°C = 180 or 60°F = 600)	W
40056	Maximum occupancy/day setpoint.	Signed Scale 10	Unit: Volts or °C/°F, Range: min to 40°C or min to 104°F Value x 10 (e.g. 3 V = 30/18°C = 180 or 60°F = 600)	W
40057	Cooling temperature setpoint in unoccupied or night mode.	Signed Scale 10	Unit: Volts or °C/°F, Range: 10°C to 40°C or 50°F to 104°F Value x 10 (e.g. 3 V = 300/18°C = 180 or 60°F = 600)	W
40058	Heating temperature setpoint in unoccupied or night mode.	Signed Scale 10	Unit: Volts or °C/°F, Range: 10°C to 40°C or 50°F to 104°F Value x 10 (e.g. 3 V = 300/18°C = 180 or 60°F = 600)	W
40059	Heating proportional band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40060	Local reheat proportional band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40061	Cooling proportional band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40062	Change over proportional band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40063	Heating dead band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40064	Local reheat dead band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W

40065	Cooling dead band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40066	Change over dead band.	Unsigned Scale 10	Unit: depends on system unit, 0.5°C to 5°C or 1°F to 9°F Value x 10 (e.g. 1°C = 10 or 2°F = 20)	W
40067	Change over setpoint.	Signed Scale 10	Unit: depends on system unit, 10°C to 40°C or 50°F to 104°F Value x 10 (e.g. 12°C = 120 or 60°F = 600)	W
40068	Fan time out in seconds.	Unsigned Scale 1	Unit: Seconds, Range: 0 to 255 seconds, Value/1 (e.g.100 secs = 100)	W
40069	Fan damping factor in seconds.	Unsigned Scale 1	Unit: Seconds, Range: 0 to 255 seconds, Value/1 (e.g.100 secs = 100)	W

Register Index	Description	Data Type	Range	Writable
40070	Heating integral time factor in seconds.	Unsigned Scale 1	Unit: Seconds, Range: 0 to 250 seconds, Value/1 (e.g.100 secs = 100)	W
40071	Cooling integral time factor in seconds.	Unsigned Scale 1	Unit: Seconds, Range: 0 to 250 seconds, Value/1 (e.g.100 secs = 100)	W
40072	Delay between cooling and heating or vice versa.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 120 minutes, Value/1 (e.g.10 mins = 10)	W
40073	Cooling anticycle delay in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 15 minutes, Value/1 (e.g.100 mins = 100)	W
40074	NSB override delay in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 180 minutes, Value/1 (e.g.100 mins = 100)	W



40075	Unoccupied override delay in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 180 minutes, Value/1 (e.g.100 mins = 100)	W
40076	Occupancy minimum time in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 240 minutes, Value/1 (e.g.100 mins = 100)	W
40077	Unoccupied override delay count down in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 180 minutes, Value/1 (e.g.100 mins = 100)	W
40078	System Control mode.	Unsigned	1= Auto   2= Heat   3= Cool   4= Heat or Cool	W
40079	Digital input 3 mode.	Unsigned	1= Off   2= Occupancy normally open   3= Occupancy normally close 4= NSB normally open   5= NSB normally close	W
40080	Override system occupancy or NSB mode. Depending on the selected DI3 mode (40079), some of these options may not be writable.	Unsigned	1= Locally   2= OFF   3= Occupied   4= Unoccupied   5= Day   6= Night	W
40081	Internal temperature sensor offset correction.	Signed Scale 100	Unit: depends on system unit, Range: $\pm 5^{\circ}\text{C}$ or $\pm 9^{\circ}\text{F}$ Value x 100 (e.g. $2^{\circ}\text{C} = 200$ or $3^{\circ}\text{F} = 300$ )	W
40082	External temperature sensor offset correction.	Signed Scale 100	Unit: depends on system unit, Range: $\pm 5^{\circ}\text{C}$ or $\pm 9^{\circ}\text{F}$ Value x 100 (e.g. $2^{\circ}\text{C} = 200$ or $3^{\circ}\text{F} = 300$ )	W
40083	Change over analog input signal.	Unsigned	3= Sensor   4= Normally Cool   5= Normally Heat	W
40084	Change over control mode.	Unsigned	1= Local   2= Cool   3= Heat	W
40085	External temperature 0-10V input on AI3.	Unsigned	1= Off   2= 2-10V   3= 0-10V	W
40086	Minimum AI3 external temperature reading.	Signed Scale 10	Unit: depends on system unit, Range: $-40^{\circ}\text{C}$ to $0^{\circ}\text{C}$ or $-40^{\circ}\text{F}$ to $32^{\circ}\text{F}$ Value x 10 (e.g. $-20^{\circ}\text{C} = -200$ or $-20^{\circ}\text{F} = 200$ )	W

40087	Maximum AI3 external temperature reading.	Signed Scale 10	Unit: depends on system unit, Range: 50°C to 100°C or 122°F to 212°F, Value x 10 (e.g. 60°C = 600 or 140°F = 1400)	W
40088	Fan output signal.	Unsigned	1= 1 speed   2= 2 speeds   3= 3 speeds   4= Analog	W

Register Index	Description	Data Type	Range	Writable
40089	Ramp to control analog output 1.	Unsigned	1= Off   2= Changeover with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W
40090	Minimum voltage for analog output 1 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40091	Maximum voltage for analog output 1 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40092	Ramp to control analog output 2.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W
40093	Minimum voltage for analog output 2 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40094	Maximum voltage for analog output 2 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40095	Ramp to control analog output 3.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W

40096	Minimum voltage for analog output 3 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40097	Maximum voltage for analog output 3 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40098	Ramp to control analog output 4.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat   7= HumidifyWithFan (with TFLHxx/TDU thermostat only)   8= Fan	W
40099	Minimum voltage for analog output 4 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40100	Maximum voltage for analog output 4 (volt).	Unsigned Scale 10	Unit: Volt, Range: 0V to 10V, Value x 10 (e.g. 3 V = 30)	W
40101	Timing of floating motor TO1-TO2 in seconds.	Unsigned Scale 1	Unit: seconds, Range: 15 to 250 seconds, Value/1 (e.g. 20 secs = 20)	W
40102	Timing of floating motor TO3-TO4 in seconds.	Unsigned Scale 1	Unit: seconds, Range: 15 to 250 seconds, Value/1 (e.g. 20 secs = 20)	W
40103	Ramp to control TRIAC output 1.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat	W

Register Index	Description	Data Type	Range	Writable
40104	Signal output configuration for TRIAC output 1.	Unsigned	1= Pulsing mode   2= On/Off mode   3= Floating mode	W
40105	TRIAC output 1 when set to close.	Unsigned Scale 1	Unit: %, Range: 15 to 80%, Value/1 (e.g. 20% = 20)	W

40106	TRIAC output 1 when set to open.	Unsigned Scale 1	Unit: %, Range: 0 to TO1closepos-4%, Value/1 (e.g. 20% = 20)	W
40107	Ramp to control TRIAC output 2.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat	W
40108	Signal output configuration for TRIAC output 2.	Unsigned	1= Pulsing mode   2= On/Off mode   3= Floating mode	W
40109	TRIAC output 2 when set to close.	Unsigned Scale 1	Unit: %, Range: 15 to 80%, Value/1 (e.g. 20% = 20)	W
40110	TRIAC output 2 when set to open.	Unsigned Scale 1	Unit: %, Range: 0 to TO2closepos-4%, Value/1 (e.g. 20% = 20)	W
40111	Ramp to control TRIAC output 3.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat	W
40112	Signal output configuration for TRIAC output 3.	Unsigned Scale 1	1= Pulsing mode   2= On/Off mode   3= Floating mode	W
40113	TRIAC output 3 when set to close.	Unsigned Scale 1	Unit: %, Range: 15 to 80%, Value/1 (e.g. 20% = 20)	W
40114	TRIAC output 3 when set to open.	Unsigned Scale 1	Unit: %, Range: 0 to TO3closepos-4%, Value/1 (e.g. 20% = 20)	W
40115	Ramp to control TRIAC output 4.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat	W
40116	Signal output configuration for TRIAC output 4.	Unsigned	1= Pulsing mode   2= On/Off mode   3= Floating mode	W
40117	TRIAC output 4 when set to close.	Unsigned Scale 1	Unit: %, Range: 15 to 80%, Value/1 (e.g. 20% = 20)	W
40118	TRIAC output 4 when set to open.	Unsigned Scale 1	Unit: %, Range: 0 to TO4closepos-4%, Value/1 (e.g. 20% = 20)	W

40119	Configuration of DO1 mode.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W
40120	Delay before activation of DO1 in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 15 minutes, Value/1 (e.g. 5 = 5 mins)	W
40121	Close position percentage for contact DO1.	Unsigned Scale 1	Unit: %, Range: 15% to 80%, Value/1 (e.g. 20% = 20)	W

Register Index	Description	Data Type	Range	Writable
40122	Open position percentage for contact DO1.	Unsigned Scale 1	Unit: %, Range: 0 to DO1closepos-4%, Value/1 (e.g. 20% = 20)	W
40123	Configuration of DO2 mode.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W

40124	Activation delay for contact DO2 in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 15 minutes, Value/1 (e.g. 5 = 5 mins)	W
40125	Close position percentage for contact DO2.	Unsigned Scale 1	Unit: %, Range: 15% to 80%, Value/1 (e.g. 20% = 20)	W
40126	Open position percentage for contact DO2.	Unsigned Scale 1	Unit: %, Range: 0 to DO2closepos-4%, Value/1 (e.g. 20% = 20)	W

40127	Configuration of DO3 mode.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W
40128	Activation delay for contact DO3 in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 15 minutes, Value/1 (e.g. 5 = 5 mins)	W
40129	Close position percentage for contact DO3.	Unsigned Scale 1	Unit: %, Range: 15% to 80%, Value/1 (e.g. 20% = 20)	W
40130	Open position percentage for contact DO3.	Unsigned Scale 1	Unit: %, Range: 0 to DO3closepos-4%, Value/1 (e.g. 20% = 20)	W
40131	Configuration of DO4 mode.	Unsigned	1= Off   2= Change Over with fan   3= Cooling with fan   4= Heating with fan 5= Local Reheat with fan   6= Local Reheat 7= HumidifyWithFan (with TFLHxx/TDU thermostat only)	W
40132	Cfg_DigitalOutput4ContactDelay.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 15 minutes, Value/1 (e.g. 5 = 5 mins)	W
40133	Cfg_DigitalOutput4ClosePos.	Unsigned Scale 1	Unit: %, Range: 15% to 80%, Value/1 (e.g. 20% = 20)	W
40134	Cfg_DigitalOutput4OpenPos.	Unsigned Scale 1	Unit: %, Range: 0 to DO4closepos-4%, Value/1 (e.g. 20% = 20)	W
40135	Digital input contact of DI1 to DI4.	Bit String	<b>[B2-B15]: Reserved</b>  B0: Digital input 1 0 = Normally Open, 1 = Normally Close B2: Digital input 3 0 = Normally Open, 1 = Normally Close	W

			BI: Digital input 2 0 = Normally Open, 1 = Normally Close	B4: Digital input 4 0 = Normally Open, 1 = Normally Close	
--	--	--	--	--	--

Register Index	Description	Data Type	Range	Writable
40136	Configuration of DI1 mode.	Unsigned	1= OFF   2= Override   3= Window   4= Door   5= DirtyFilter   6= FlowSwitch 7= OverHeat	W
40137	Delay before activation of DI1 in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 65,535 minutes, Value/1 (e.g. 5 = 5 mins)	W
40138	Configuration of DI2 mode.	Unsigned	1= OFF   2= Override   3= Window   4= Door   5= DirtyFilter   6= FlowSwitch 7= OverHeat	W
40139	Delay before activation of DI2 in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 65,535 minutes, Value/1 (e.g. 5 = 5 mins)	W
40140	Configuration of DI4 mode.	Unsigned	1= OFF   2= Override   3= Window   4= Door   5= DirtyFilter   6= FlowSwitch 7= OverHeat	W
40141	Delay before activation of DI4 in minutes.	Unsigned Scale 1	Unit: Minutes, Range: 0 to 65,535 minutes, Value/1 (e.g. 5 = 5 mins)	W
40142	Humidity control mode status. Not available on all models.	Unsigned	1= Auto   2= Dehumidification   3= Humidification   4= Off	W

40143	Humidity setpoint (%RH) in occupancy or day mode. Not available on all models.	Unsigned Scale 10	Unit: %RH, Limited by min/max humidity setpoint, Value x 10 (e.g. 20%RH = 200)	W
40144	Dehumidification setpoint (%RH) in unoccupied or night mode. Not available on all models.	Unsigned Scale 10	Unit: %RH, Range: 10% to 65%, Value x 10 (e.g. 20%RH = 200)	W
40145	Humidification setpoint (%RH) in unoccupied or night mode. Not available on all models.	Unsigned Scale 10	Unit: %RH, Range: 10% to 65%, Value x 10 (e.g. 20%RH = 200)	W
40146	Minimum user setpoint. Not available on all models.	Unsigned Scale 10	Unit: %RH, Range: 10% to max, Value x 10 (e.g. 20%RH = 200)	W
40147	Maximum user setpoint. Not available on all models.	Unsigned Scale 10	Unit: %RH, Range: min to 65%, Value x 10 (e.g. 20%RH = 200)	W
40148	Humidity proportional band. Not available on all models.	Unsigned Scale 10	Unit: %RH, Range: 3%RH to 10%RH, Value x 10 (e.g. 4%RH = 40)	W
40149	Cfg_HumDeadBand. Not available on all models.	Unsigned Scale 10	Unit: %RH, Range: 0% to 5%, Value x 10 (e.g. 4%RH = 40)	W
40150	External humidity sensor input.	Unsigned	1= Off   2= Analog input 3   3= Analog input 4   4= Analog input 5   5= Analog input 6	W
40151	Internal humidity sensor offset correction. Not available on all models.	Signed Scale 10	Unit: %RH, Range: $\pm$ 5%RH, Value x 10 (e.g. 2%RH = 20)	W

Register Index	Description	Data Type	Range	Writable
----------------	-------------	-----------	-------	----------



40152	External humidity sensor offset correction. Not available on all models.	Signed Scale 10	Unit: %RH, Range: $\pm 5\%RH$ , Value x 10 (e.g. 2%RH = 20)	W
40153	Internal CO <sub>2</sub> sensor reading. Not available on all models.	Unsigned Scale 1	Unit: PPM, Range: 0 to 2000 PPM, Value x 1 (e.g. 20PPM = 20)	RO

---

## Notes

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---



oneSIGHT  
SOLUTIONS